

314 CMR: DIVISION OF WATER POLLUTION CONTROL: excerpts from 405: Class B and SB Water Quality Criteria, Narrative Nutrient Criteria, and 403: Application of Standards for Establishment of Effluent Limitations – [click this link for the full standards on mass.gov](#)

#### WATER QUALITY CRITERIA FOR CLASS B WATERS:

(b) Class B. These waters are designated as a habitat for fish, other aquatic life, and wildlife, including for their reproduction, migration, growth and other critical functions, and for primary and secondary contact recreation. Where designated in 314 CMR 4.06, they shall be suitable as a source of public water supply with appropriate treatment (“Treated Water Supply”). Class B waters shall be suitable for irrigation and other agricultural uses and for compatible industrial cooling and process uses. These waters shall have consistently good aesthetic value.

1. Dissolved Oxygen.

a. Shall not be less than 6.0 mg/l in cold water fisheries and not less than 5.0 mg/l in warm water fisheries. Where natural background conditions are lower, DO shall not be less than natural background conditions. Natural seasonal and daily variations that are necessary to protect existing and designated uses shall be maintained.

2. Temperature.

a. Shall not exceed 68°F (20°C) based on the mean of the daily maximum temperature over a seven day period in cold water fisheries, unless naturally occurring. Where a reproducing cold water aquatic community exists at a naturally occurring higher temperature, the temperature necessary to protect the community shall not be exceeded and the natural daily and seasonal temperature fluctuations necessary to protect the community shall be maintained. Temperature shall not exceed 83°F (28.3°C) in warm water fisheries. The rise in temperature due to a discharge shall not exceed 3°F (1.7°C) in rivers and streams designated as cold water fisheries nor 5°F (2.8°C) in rivers and streams designated as warm water fisheries (based on the minimum expected flow for the month); in lakes and ponds the rise shall not exceed 3°F (1.7°C) in the epilimnion (based on the monthly average of maximum daily temperature);

b. natural seasonal and daily variations that are necessary to protect existing and designated uses shall be maintained. There shall be no changes from natural background conditions that would impair any use assigned to this Class, including those conditions necessary to protect normal species diversity, successful migration, reproductive functions or growth of aquatic organisms;

c. alternative effluent limitations established in connection with a variance for a thermal discharge issued under 33 U.S.C. § 1251 (FWPCA, § 316(a)) and 314 CMR 3.00 are in compliance with 314 CMR 4.00. As required by 33 U.S.C. § 1251 (FWPCA, § 316(a)) and 314 CMR 3.00, for permit and variance renewal, the applicant must demonstrate that alternative effluent limitations continue to comply with the variance standard for thermal discharges; and

d. in the case of a cooling water intake structure (CWIS) regulated by EPA under 33 U.S.C. § 1251 (FWPCA § 316(b)), the Department has the authority under 33 U.S.C. § 1251 (FWPCA § 401), M.G.L. c. 21, §§ 26 through 53 and 314 CMR 3.00 to condition the CWIS to assure compliance of the withdrawal activity with 314 CMR 4.00, including, but not limited to, compliance with narrative and numerical criteria and protection of existing and designated uses.

3. pH. Shall be in the range of 6.5 through 8.3 standard units and not more than 0.5 units outside of the natural background range. There shall be no change from natural background conditions that would impair any use assigned to this Class.

4. Bacteria.

a. At bathing beaches as defined by the Massachusetts Department of Public Health in 105 CMR 445.010: where E. coli is the chosen indicator, the geometric mean of the five most recent samples taken during the same bathing season shall not exceed 126 colonies per 100 ml and no single sample taken during the bathing season shall exceed 235 colonies per 100 ml; alternatively, where enterococci are the chosen indicator, the geometric mean of the five most recent samples taken during the same bathing season shall not exceed 33 colonies per 100 ml and no single sample taken during the bathing season shall exceed 61 colonies per 100 ml;

b. for other waters and, during the non bathing season, for waters at bathing beaches as defined by the Massachusetts Department of Public Health in 105 CMR 445.010: the geometric mean of all E. coli samples taken within the most recent six months shall not exceed 126 colonies per 100 ml typically based on a minimum of five samples and no single sample shall exceed 235 colonies per 100 ml; alternatively, the geometric mean of all enterococci samples taken within the most recent six months shall not exceed 33 colonies per 100 ml typically based on a minimum of five samples and no single sample shall exceed 61 colonies per 100 ml. These criteria may be applied on a seasonal basis at the discretion of the Department; and

c. consistent with Massachusetts Department of Public Health regulations for bathing beaches, the single sample maximum values in the primary contact bacteria criteria in 314 CMR 4.05(3)(b)4.a. and 4.05(3)(b)4.b. also are for use in the context of notification and closure decisions.

5. Solids. These waters shall be free from floating, suspended and settleable solids in concentrations and combinations that would impair any use assigned to this Class, that would cause aesthetically objectionable conditions, or that would impair the benthic biota or degrade the chemical composition of the bottom.

6. Color and Turbidity. These waters shall be free from color and turbidity in concentrations or combinations that are aesthetically objectionable or would impair any use assigned to this Class.

7. Oil and Grease. These waters shall be free from oil, grease and petrochemicals that produce a visible film on the surface of the water, impart an oily taste to the water or an oily or other undesirable taste to the edible portions of aquatic life, coat the banks or bottom of the water course, or are deleterious or become toxic to aquatic life.

8. Taste and Odor. None in such concentrations or combinations that are aesthetically objectionable, that would impair any use assigned to this Class, or that would cause tainting or undesirable flavors in the edible portions of aquatic life.

#### WATER QUALITY CRITERIA FOR CLASS SB WATERS:

(b) Class SB. These waters are designated as a habitat for fish, other aquatic life and wildlife, including for their reproduction, migration, growth and other critical functions, and for primary and secondary contact recreation. In certain waters, habitat for fish, other aquatic life and wildlife may include, but is not limited to, seagrass. Where designated in the tables to 314

CMR 4.00 for shellfishing, these waters shall be suitable for shellfish harvesting with depuration (Restricted and Conditionally Restricted Shellfish Areas). These waters shall have consistently good aesthetic value. In the case of a water intake structure (IS) at a desalination facility, the Department has the authority under 33 U.S.C. § 1251 (FWPCA § 401), M.G.L. c. 21, §§ 26 through 53 and 314 CMR 3.00 to condition the IS to assure compliance of the withdrawal activity with 314 CMR 4.00, including, but not limited to, compliance with the narrative and numerical criteria and protection of existing and designated uses.

1. Dissolved Oxygen. Shall not be less than 5.0 mg/l. Seasonal and daily variations that are necessary to protect existing and designated uses shall be maintained. Where natural background conditions are lower, DO shall not be less than natural background.

2. Temperature.

a. Shall not exceed 85°F (29.4°C) nor a maximum daily mean of 80°F (26.7°C), and the rise in temperature due to a discharge shall not exceed 1.5°F (0.8°C) during the summer months (July through September) nor 4°F (2.2°C) during the winter months (October through June);

b. there shall be no changes from natural background that would impair any uses assigned to this class including those conditions necessary to protect normal species diversity, successful migration, reproductive functions or growth of aquatic organisms;

c. alternative effluent limitations established in connection with a variance for a thermal discharge issued under 33 U.S.C. § 1251 (FWPCA, § 316(a)) and 314 CMR 3.00 are in compliance with 314 CMR 4.00. As required by 33 U.S.C. § 1251 (FWPCA, § 316(a)) and 314 CMR 3.00, for permit and variance renewal, the applicant must demonstrate that alternative effluent limitations continue to comply with the variance standard for thermal discharges; and

d. in the case of a cooling water intake structure (CWIS) regulated by EPA under 33 U.S.C. § 1251 (FWPCA § 316(b)), the Department has the authority under 33 U.S.C. § 1251 (FWPCA § 401), M.G.L. c. 21, §§ 26 through 53 and 314 CMR 3.00 to condition the CWIS to assure compliance of the withdrawal activity with 314 CMR 4.00, including, but not limited to, compliance with narrative and numerical criteria and protection of existing and designated uses.

3. pH. Shall be in the range of 6.5 through 8.5 standard units and not more than 0.2 units outside of the natural background range. There shall be no change from natural background conditions that would impair any use assigned to this Class.

4. Bacteria.

a. Waters designated for shellfishing shall not exceed a fecal coliform median or geometric mean MPN of 88 organisms per 100 ml, nor shall more than 10% of the samples exceed an MPN of 260 per 100 ml or other values of equivalent protection based on sampling and analytical methods used by the Massachusetts Division of Marine Fisheries and approved by the National Shellfish Sanitation Program in the latest revision of the Guide For The Control of Molluscan Shellfish (more stringent regulations may apply, see 314 CMR 4.06(1)(d)(5));

b. at bathing beaches as defined by the Massachusetts Department of Public Health in 105 CMR 445.010, no single enterococci sample taken during the bathing season shall exceed 104 colonies per 100 ml and the geometric mean of the five most recent samples taken within the same bathing season shall not exceed 35 enterococci colonies

per 100 ml. In non bathing beach waters and bathing beach waters during the non bathing season, no single enterococci sample shall exceed 104 colonies per 100 ml and the geometric mean of all of the samples taken during the most recent six months typically based on a minimum of five samples shall not exceed 35 enterococci colonies per 100 ml. These criteria may be applied on a seasonal basis at the discretion of the Department; and

c. consistent with Massachusetts Department of Public Health regulations for bathing beaches, the single sample maximum values in the primary contact recreation bacteria criteria in 314 CMR 4.05(4)(b)4.b. also are for use in the context of notification and closure decisions.

5. Solids. These waters shall be free from floating, suspended and settleable solids in concentrations or combinations that would impair any use assigned to this class, that would cause aesthetically objectionable conditions, or that would impair the benthic biota or degrade the chemical composition of the bottom.

6. Color and Turbidity. These waters shall be free from color and turbidity in concentrations or combinations that are aesthetically objectionable or would impair any use assigned to this class.

7. Oil and Grease. These waters shall be free from oil, grease and petrochemicals that produce a visible film on the surface of the water, impart an oily taste to the water or an oily or other undesirable taste to the edible portions of aquatic life, coat the banks or bottom of the water course, or are deleterious or become toxic to aquatic life.

8. Taste and Odor. None in such concentrations or combinations that are aesthetically objectionable, that would impair any use assigned to this class, or that would cause tainting or undesirable flavors in the edible portions of aquatic life.

#### ADDITIONAL MINIMUM CRITERIA APPLICABLE TO ALL SURFACE WATERS.

[note: includes the narrative nutrients criterion (c) below which permit writers are required to interpret and develop into a numeric instream criterion case by case when writing a permit; and an excerpt from 4.03 (1) (a) Establishment of Effluent Limitations from the Application of Standards portion of the regulation]

(a) Aesthetics. All surface waters shall be free from pollutants in concentrations or combinations that settle to form objectionable deposits; float as debris, scum or other matter to form nuisances; produce objectionable odor, color, taste or turbidity; or produce undesirable or nuisance species of aquatic life.

(b) Bottom Pollutants or Alterations. All surface waters shall be free from pollutants in concentrations or combinations or from alterations that adversely affect the physical or chemical nature of the bottom, interfere with the propagation of fish or shellfish, or adversely affect populations of non-mobile or sessile benthic organisms.

(c) Nutrients. Unless naturally occurring, all surface waters shall be free from nutrients in concentrations that would cause or contribute to impairment of existing or designated uses and shall not exceed the site specific criteria developed in a TMDL or as otherwise established by the Department pursuant to 314 CMR 4.00. Any existing point source discharge containing nutrients in concentrations that would cause or contribute to cultural eutrophication, including the excessive growth of aquatic plants or algae, in any surface water shall be provided with the most appropriate treatment as determined by the Department, including, where necessary, highest and

best practical treatment (HBPT) for POTWs and BAT for non POTWs, to remove such nutrients to ensure protection of existing and designated uses. Human activities that result in the nonpoint source discharge of nutrients to any surface water may be required to be provided with cost effective and reasonable best management practices for nonpoint source control.

(d) Radioactivity. All surface waters shall be free from radioactive substances in concentrations or combinations that would be harmful to human, animal or aquatic life or the most sensitive designated use; result in radionuclides in aquatic life exceeding the recommended limits for consumption by humans; or exceed Massachusetts Drinking Water Regulations as set forth in 310 CMR 22.09.

(e) Toxic Pollutants. All surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife. For pollutants not otherwise listed in 314 CMR 4.00, the National Recommended Water Quality Criteria: 2002, EPA 822R-02-047, November 2002 published by EPA pursuant to Section 304(a) of the Federal Water Pollution Control Act, are the allowable receiving water concentrations for the affected waters, unless the Department either establishes a site specific criterion or determines that naturally occurring background concentrations are higher. Where the Department determines that naturally occurring background concentrations are higher, those concentrations shall be the allowable receiving water concentrations. The Department shall use the water quality criteria for the protection of aquatic life expressed in terms of the dissolved fraction of metals when EPA's 304(a) recommended criteria provide for use of the dissolved fraction. The EPA recommended criteria based on total recoverable metals shall be converted to dissolved metals using EPA's published conversion factors. Permit limits will be written in terms of total recoverable metals. Translation from dissolved metals criteria to total recoverable metals permit limits will be based on EPA's conversion factors or other methods approved by the Department. The Department may establish site specific criteria for toxic pollutants based on site specific considerations. Site specific criteria, human health risk levels and permit limits will be established in accordance with the following:

1. Site Specific Criteria: Where EPA recommended criteria for a specific pollutant are not available or where the Department determines that they are invalid due to site specific physical, chemical or biological considerations, the Department shall use a site specific criterion as the allowable receiving water concentration for the affected waters. In all cases, at a minimum, site specific criteria shall not exceed safe exposure levels determined by toxicity testing using methods approved by the Department. The Department will adopt any such site specific criteria as revisions to 314 CMR 4.00 in accordance with M.G.L. c. 30A.
2. Human Health Risk Levels. Where EPA has not set human health risk levels for a toxic pollutant, the human health based regulation of the toxic pollutant shall be in accordance with guidance issued by the Department of Environmental Protection's Office of Research and Standards. The Department's goal is to prevent all adverse health effects which may result from the ingestion, inhalation or dermal absorption of toxins attributable to waters during their reasonable use as designated in 314 CMR 4.00. When this goal is not attainable, the Department will use a goal of 10<sup>-6</sup> as the acceptable excess lifetime cancer risk level for individual carcinogens.
3. Accumulation of Pollutants. Where appropriate the Department shall use an additional margin of safety when establishing water quality based effluent limits to assure that pollutants do not persist in the environment or accumulate in organisms to levels that:

- a. are toxic to humans, wildlife or aquatic life; or
- b. result in unacceptable concentrations in edible portions of marketable fish or shellfish or for the recreational use of fish, shellfish, other aquatic life or wildlife for human consumption

#### 4.03: Application of Standards

- (1) (a) Establishment of Effluent Limitations. The Department will limit or prohibit discharges of pollutants to surface waters to assure that surface water quality standards of the receiving waters are protected and maintained or attained. The level of treatment for an individual discharger will be established by the discharge permit in accordance with 314 CMR 3.00 (Massachusetts Surface Water Discharge Permit Program). In establishing water quality based effluent limitations the Department shall take into consideration natural background conditions and existing discharges. Discharges shall be limited or prohibited to protect existing uses and not interfere with the attainment of designated uses in downstream and adjacent segments. The Department will provide a reasonable margin of safety to account for any lack of knowledge concerning the relationship between the pollutants being discharged and their impact on water quality. Where the Department has not established water quality based effluent limitations in a permit and a violation of water quality standards attributable to a discharge occurs, the Department may modify, suspend or revoke the permit, in whole or in part, for cause in accordance with 314 CMR 3.00.